



CHERRY HILL FIRE MARSHAL'S OFFICE

AUTOMATIC SPRINKLER SYSTEM TEST REPORT

**Only this document will be accepted by the Cherry Hill Fire Prevention Division for annual testing purposes as required by the New Jersey Uniform Fire Safety Code and applicable N.F.P.A. standards.

PROPERTY NAME: _____ DATE OF INSPECTION: ____/____/____

PROPERTY ADDRESS: _____ INSPECTOR: _____

TESTING AGENCY NAME: _____

NJ-DFS BUSINESS PERMIT # _____ PHONE # _____

TESTING AGENCY ADDRESS _____

- 1. TYPE OF SYSTEM: [] WET [] DRY PIPE [] PRE ACTION [] ANTI-FREEZE [] DELUGE
2. LOCATION OF MAIN SHUTOFF VALVE: _____
3. NUMBER OF RISERS ON SYSTEM: _____ ARE THEY PROPERLY IDENTIFIED? [] YES [] NO
4. SHUTOFF VALVE TYPE: [] O S & Y [] P.I.V. [] WALL INDICATOR
5. ANY SYSTEM MODIFICATIONS SINCE LAST INSPECTION? [] YES [] NO IF YES, EXPLAIN _____
6. SPRINKLER HEADS TYPE _____ MANUFACTURER _____ MODEL _____
TEMP RATING _____ YEAR MANUFACTURED _____
7. DATE OF LAST FLOW TEST: ____/____/____ AVAIL FLOW: _____ GPM
FIRE PUMP? [] YES [] NO TYPE: [] DIESEL [] ELECTRIC [] GASOLINE [] OTHER
JOCKEY PUMP? [] YES [] NO
8. DATE OF LAST FIRE PUMP TEST: ____/____/____ GENERAL PUMP CONDITION: _____
9. LOCATION OF F.D. CONNECTION: _____ SIGN PROVIDED? [] YES [] NO
F.D. CONNECTION TYPE: [] 2 1/2" N.S.T. [] 4" STORZ
10. PRESSURE READING: STATIC: _____ P.S.I. 2" FLOW: _____ P.S.I.
INSPECTOR TEST VALVE: _____ P.S.I.
11. DOES FIRE ALARM SYSTEM RESPOND TO WATER FLOW AND TAMPER SIGNALS? [] YES [] NO [] N/A
12. DATE OF LAST INTERNAL PIPE INSPECTION? ____/____/____ RESULTS? _____
13. ARE ALL SPRINKLER HEADS UNOBSTRUCTED, CORRECT, AND SERVICEABLE? [] YES [] NO
IF NO, EXPLAIN IN "NOTES" SECTION.
14. SUPERVISION OF VALVES: [] SEALED [] LOCKED [] TAMPER SWITCH [] WHEEL REMOVED
15. ARE ALL SPRINKLER VALVES IDENTIFIED WITH SIGNS? [] YES [] NO
16. IS BUILDING VALVE ROOM HEATED? [] YES [] NO
17. IF DRY PIPE SYSTEM, WAS DRY PIPE VALVE TRIPPED, CLEANED, RESET? [] YES [] NO
18. IS DRY SYSTEM SUPERVISED FOR LOW AIR PRESSURE? [] YES [] NO
19. ALL THREADS AND CONNECTIONS COMPATIBLE WITH CHERRY HILL FIRE DEPARTMENT EQUIPMENT?
[] 1 1/2" N.S.T. [] 2 1/2" N.S.T. [] 4 1/2" N.S.T. [] 4" STORZ [] 4 1/2" NJ WATER THREAD

